



Community Development Department • Building Inspection Division  
500 Castro Street • Post Office Box 7540 • Mountain View, California 94039-7540 • 650-903-6313 • FAX 650-903-6474

**NO PARKING FIRE LANE SIGN**  
(FUSED PORCELAIN CERAMIC ENAMEL SIGN FOR EXTERIOR USE)

**Sign**



Steel: 18 ga. ASTM A-424 Type II  
Color: Red on White, Reflective B/G  
Size: 12" x 18"  
Mounting: single face with sign installed on each side of the post (two signs installed back-to-back)

**Pipe:**

2" I.D. Galv. Pipe  
10'6" in length  
Minimum 2' bury  
(Alternate methods of attaching signs may be approved by the Fire Protection Engineer)

California Vehicle Code Section 22500.1

**GUIDELINES FOR AUTHORIZING AND MARKING FIRE LANES  
ON PRIVATE PROPERTY**

1. Only a Fire Department representative has the authority to designate Fire Lanes.
2. The property owner is required to post and maintain Fire Lanes.
3. To post authorized Fire Lanes, install approved "NO PARKING FIRE LANE" signs immediately adjacent to, and visible from, the designated fire lane. (Specific locations and frequency as directed by the Fire Protection Engineer).
4. Signs shall be modeled as identified below:

NO PARKING]-----[4" high, 1/2" stroke  
FIRE LANE]-----[2" high  
CVC. Sect. 22500.1, CITY ORD. 19.80]-----[1/8" stroke  
(\*Red letters on a white background.)

5. Boundaries of restricted parking areas shall be designated with red paint and white stencil on the horizontal (top) of curbs and/or pavement.
6. Violators should be reported to the Mountain View Police Department.